



# NOTICE OF FIRE HAZARD INSPECTION

A fire department representative has inspected your property for fire hazards. You are hereby notified to correct the violation(s) indicated below.  
**Failure to correct these violations may result in a citation and fine.**

Occupant:		Physical Address:			Phone #:		
Occupant Not Home: 1 <sup>st</sup> Attempt: ___/___/___		Occupant Not Home: 2 <sup>nd</sup> Attempt: ___/___/___		Refused Inspection: ___/___/___		For Questions, Contact Inspector at: (_____) _____	
Roof Construction Combustible/Non-Combustible	Exterior Siding Combustible/Non-Combustible	Window Panes Single Pane/Multi-Pane	Eaves Enclosed/Unenclosed	Decks or Porches Masonry/Composite/Wood	Location of Structure Flat Ground/Slope/Ridge Top		

Checked boxes indicate violations.

**Corrected** **Defensible Space Zone (within 30 feet of all structures or to property line):**

- 2 3 A. Remove all branches within 10 feet of any stovepipe or chimney outlet. PRC §4291(a)(4)
- 2 3 B. Remove leaves, needles or other vegetation on roofs, gutters, decks, porches and stairways etc. PRC §4291(a)(6)
- 2 3 C. Remove all dead or dying trees, branches, shrubs or other plants adjacent to or overhanging buildings. PRC §4291(a)(5)
- 2 3 D. Prune lower branches of trees to a height of 6 to 15 feet (or 1/3 tree height for trees under 18 feet). PRC §4291(a)(1)
- 2 3 E. Remove all dead or dying grass, leaves, needles or other vegetation. PRC §4291(a)(1)
- 2 3 F. Remove or separate live flammable ground cover and shrubs. PRC §4291(a)(1)

**Reduced Fuel Zone (within 30 - 100 feet of all structures or to property line):**

- 2 3 G. Mow dead or dying grass to a maximum of 4 inches in height. Trimmings may remain on the ground. PRC §4291(a)(1)
- 2 3 H. Live flammable ground cover less than 18 inches in height may remain, but overhanging and adjacent trees must be pruned to a height of 6 to 15 feet. PRC §4291(a)(1)
- 2 3 I. Reduce fuels in accordance with the Continuous Tree Canopy Standard (see back). PRC §4291(a)(1)
- 2 3 J. Reduce fuels in accordance with the Horizontal Spacing Standard (see back). PRC §4291(a)(1)

**Defensible and Reduced Fuel Zone (within 100 feet of all structures or to property line):**

- 2 3 K. Logs or stumps embedded in the soil must be removed or isolated from structures and other vegetation. PRC §4291(a)(1)
- 2 3 L. Remove all dead or dying brush and trees, and all dead or dying tree branches within 15 feet of the ground. PRC §4291(a)(1)

**Other Requirements:**

- 2 3 M. Clear all flammable vegetation, trash and other combustible materials 10 feet around and above propane tanks. CFC §3807.3
- 2 3 N. Address numbers shall be displayed in contrasting colors (4" Min. Size) and readable from the street or access road. CFC §505.1
- 2 3 O. Equip chimney or stovepipe openings with a metal screen having openings between 3/8 inch and 1/2 inch. CBC §2113.9.1

**Recommendations:**

- Clear 10 feet around and 15 feet above fuels (e.g. Woodpiles, lumber, scrap etc.). Move woodpiles as far as possible from structures.
- Remove flammable materials stored under decks and similar overhangs of structures.
- Clear vegetation 10 feet from sides and 15 feet above all driveways and turnaround areas.

**No violations observed.**

**Comments:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Additional Information on Back**

1. Inspector: _____	Date: ___/___/___	A re-inspection will occur on/after: ___/___/___
2. Inspector: _____	Date: ___/___/___	A re-inspection will occur on/after: ___/___/___
3. Inspector: _____	Date: ___/___/___	